



GENERAL NOTES:

- A. CONCEALED CABLE TRAY INSTALLED ABOVE CEILING TILE DOES NOT REQUIRE BOTTOM TRAY AND TOP COVER FITTINGS. PROVIDE TRAY AND COVER FOR EXPOSED CABLE TRAY ONLY.
- B. SUPPORT CABLES FROM CABLE TRAY TO 1" CONDUIT STUB OF OUTLET BOX WITH J-HOOKS ABOVE SUSPENDED CEILING. INSTALL J-HOOKS ON 48" CENTERS.
- C. PROVIDE MINIMUM OF 1" SLEEVED PENETRATION OF WALLS EXTENDING TO OVERHEAD STRUCTURE WHERE REQUIRED FOR ROUTING CABLE TO OUTLET BOXES. PROVIDE 1" SLEEVE FOR EACH OUTLET BOX SERVED.

SHEET NOTES:

1. EXPOSED 2-4" CONDUITS DOWN TO FLOOR BELOW. FIRESTOP FLOOR PENETRATIONS. PAINT SUPPORTS AND CONDUIT TO MATCH WALL.
2. EXPOSED 2-4" CONDUITS WITH 90 DEGREE BENDS TIGHT TO CEILING. CONNECT TO CONDUITS UP FROM FLOOR BELOW AND EXTEND THROUGH CORRIDOR WALL TO CABLE TRAY. BOND CONDUITS TO CABLE TRAY. PAINT FITTINGS AND CONDUIT TO MATCH CEILING.
3. 12" WIDE X 2" HIGH WIRE MESH CABLE TRAY ABOVE SUSPENDED CEILING. INSTALL ALONG FULL LENGTH OF CORRIDOR AS SHOWN AND SUPPORT ON WALL AT BOTH ENDS. PROVIDE DIAGONAL SUPPORTS AS REQUIRED TO RESTRICT LATERAL SWAY.
4. OUTLET FOR HORIZONTAL COMMUNICATIONS CABLING TO WORK AREA. DOUBLE GANG BOX WITH SINGLE GANG MUD RING AND 1" CONDUIT STUB UP TO ACCESSIBLE VOID ABOVE CEILING. 3 CAT-6 CABLES FROM TELECOMMUNICATIONS ROOM G07.
5. OUTLET FOR ELEVATOR CAB PHONE INSTALLED IN ELEVATOR EQUIPMENT CONTROL CABINET. COORDINATE WITH ELEVATOR SERVICE PROVIDER AND INSTALL CABLE PER MANUFACTURER'S RECOMMENDATIONS.

THIRD FLOOR
1TELECOMMUNICATIONS PLAN

0' 4' 8' 12' 16' 20' 24'

SCALE: 1/4" = 1'-0"

95% SUBMISSION

CSHQ&A

C.W. MOORE PLAZA
250 S. 6TH ST. - BOISE, ID 83702
(208) 343-4835 • FAX (208) 343-1858
http://www.cshqa.com

AMY E. DOCKTER, P.E.
C.W. MOORE PLAZA
250 S. 6TH ST.
BOISE, IDAHO
PHONE: 208-343-4835 FAX: 208-343-1858

THESE DRAWINGS AND SPECIFICATIONS, AS INSTRUMENTS OF SERVICE, ARE AND SHALL REMAIN THE PROPERTY OF THE ARCHITECT. I HEREBY WARRANT THE PROJECT FOR WHICH THEY ARE MADE IS EXECUTED ON MY PART. THESE DRAWINGS AND SPECIFICATIONS SHALL NOT BE USED BY ANY PERSON OR ENTITY ON OTHER PROJECTS, FOR ADDITIONS TO THIS PROJECT, OR COMPLETION OF THIS PROJECT, WITHOUT THE WRITTEN CONSENT OF CSHQA OR ITS AFFILIATES. Copyright 1991

PRELIMINARY
NOT FOR
CONSTRUCTION

DRAWING TITLE
THIRD FLOOR
TELECOMMUNICATIONS PLAN

APPROVED: DIVISION CHIEF

APPROVED: SERVICE DIRECTOR

PROJECT TITLE
VAMC
RENOVATE
BUILDING 33

BUILDING NUMBER
33

CHECKED
AKD

DRAWN
JDR

LOCATION
BOISE, IDAHO

DATE
03/04/11

PROJECT NO.
531-10-114

DRAWING NO.

E2.11

DWG. 92 OF 102

